

Iesire mg/l

Data	pH	Suspensii	CBO5	CCOCr	Extr.	*Fosf. Total	*Deterg.	*Azot total	Reziduu
1	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*
3	7.40	33.00	*	102.00	*	*	*	*	*
4	7.50	34.00	*	*	*	1.880	*	*	*
5	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*
7	7.20	33.00	*	77.30	*	*	*	*	*
8	6.80	*	*	*	*	1.830	*	14.80	*
9	7.50	19.00	17.80	71.39	<2(2.0)	1.800	0.17	12.70	738.00
10	7.10	29.00	*	73.10	*	*	*	*	*
11	7.10	34.00	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*
14	7.20	*	*	84.80	*	*	*	12.70	*
15	7.20	*	*	*	*	*	*	*	*
16	7.45	25.00	23.90	104.80	<2(2.4)	*	*	11.30	822.00
17	7.10	*	*	97.00	*	1.720	*	*	*
18	7.20	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	1.210	*	*	*
21	7.00	30.00	*	74.30	*	*	*	10.70	*
22	7.00	34.00	*	*	*	*	*	*	*
23	7.39	34.00	20.76	69.79	<2(2.8)	1.020	0.26	13.00	714.00
24	*	*	*	*	*	*	*	*	*
25	7.20	33.00	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	0.718	*	*	*
28	7.40	28.00	*	73.40	*	0.945	*	11.40	*
29	7.20	*	*	*	*	*	*	*	*
30	7.07	23.00	21.70	106.24	*	1.150	*	13.50	*
31	7.20	*	*	88.60	*	0.980	*	*	*
Media	7.21	29.92	21.04	85.23	2.40	1.33	0.22	12.51	758.00

Încercările marcate cu * si/sau hasurate NU sunt acoperite de acreditarea RENAR
Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei
Prezenta raportare este doar pentru uzul intern

Şef laborator
 chim. Hegedus Erika

