

mg/l

Data	pH	Suspensii	CBO5	CCO-Cr	Extractibile	Amoniu	Reziduu	*Detergenti
1	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*
3	7.38	101.00	74.30	185.92	<20(14.0)	27.600	508.00	0.380
4	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*
10	7.60	50.00	63.74	151..68	<20(14.0)	24.500	498.00	0.380
11	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*
17	7.58	71.00	57.48	137.20	<20(9.6)	29.000	*	0.300
18	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*
24	7.56	310.00	37.38	164.03	<20(6.4)	26.800	510.00	0.320
25	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*
Media	7.530	133.000	58.225	162.383	11.000	26.975	505.333	0.345
CMA	6.5-8.5	350.00	300	500	30	30	2000	25

**Încercările marcate cu \* si/sau hasurate NU sunt acoperite de acreditarea RENAR**

**Rezultatele notate cu "<" reprezinta valorile situate sub limita de determinare a metodei**

**Prezenta raportare este doar pentru uzul intern**

Șef laborator

chim. Hegedus Erika