

IESIRE												
-mg/l -												
Data	pH	Susp. Tot.	CBO5	CCO- Cr	Extr.	Amoniu	*Fosfor tot.	*Deterg.	*Cianuri	*Sulfați	*Crom total	Zinc
1	*	*	*	*	*	*	*	*	*	*	*	*
2	7.03	3.80	7.70	<30(29.95)	<20(4.8)	3.15	4.43	0.13	0.00	70.00	0.00	0.00
3	*	*	*	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*	*
5	7.04	28.00	9.76	38.84	*	0.159	3.39	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*	*
13	7.11	8.00	10.49	42.24	*	0.290	0.90	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*	*
19	7.12	11.00	10.89	41.71	*	0.172	1.84	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*	*
30	7.30	8.00	11.63	44.81	<20(3.6)	0.151	1.51	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*	*
Media	7.12	11.76	10.09	39.51	4.20	0.78	2.41	0.13	0.00	70.00	0.00	0.00
CMA	6.5-8.5	3500	300	500	30	30	15	25	1	600	1.5	1

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
 Responsabil calitate

Avizat
 Șef laborator