

Iesire Stație -mg/l-

Data	pH	Susp. totale	CBO5	CCO- Cr		Extr.	*Fosfor total	*Deterg.	*Azot total	Reziduu	Amoniu	Azotati	N-Azotati
1	*	*	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*	*	*
3	6,59	4,0	2,02	<30	22,69	<20(2.0)	1,3	0,1	9,4	302	0,037	25,90	5,86
4	6,76	2,0	5	*	14,6	*	*	*	*	*	*	*	*
5	6,74	2,0	*	*	*	*	0,522	*	8	*	0,035	30,63	6,9
6	6,71	2,0	4	*	11,6	*	*	*	*	*	*	*	*
7	6,75	2,0	*	*	*	*	*	0,339	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*	*	*
10	6,63	2,0	5,77	<30	24,16	*	0,471	*	10	*	0,054	39,07	8,8
11	7,43	2,0	6	*	15,2	*	*	*	*	*	*	*	*
12	7,47	2,0	*	*	*	*	0,517	*	10,7	*	0,036	39,96	9
13	7,49	2,0	6	*	15,1	*	*	*	*	*	*	*	*
14	7,52	2,0	*	*	*	*	0,561	0,586	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*	*	*
17	6,72	8,0	7,22	<30	28,94	*	0,621	*	9,7	*	0,482	34,40	7,76
18	7,49	4,0	5	*	12,5	*	*	0,274	*	*	*	*	*
19	7,44	4,0	*	*	*	*	0,689	*	9,00	*	*	35,52	8
20	7,52	3,0	5	*	14,3	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*	*
24	6,99	12,0	5,78	<30	22,92	*	0,8	*	9,7	*	0,572	*	*
25	*	*	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*	*	*
Media	7,083	3,533	5,179	*	18,201	2,000	0,685	0,325	9,500	302,000	0,203	34,247	7,720
CMA													

Încercările marcate cu \* sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit  
Responsabil calitate

Avizat  
Șef laborator