

Iesire Stație -mg/l-

Data	pH	Susp. totale	CBO5	CCO- Cr		Extr.	*Fosfor total	*Deterg.	*Azot total	Reziduu	Amoniu	Azotati	N-Azotati
1	*	*	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*	*	*
3	6,95	4,0	3,0	*	13,6	*	*	*	6,09	*	0,043	21,30	4,8
4	7,2	3,0	2,0	*	11,2	*	0,834	*	5,18	*	0,111	17,80	4,02
5	7,18	3,0	3,0	*	12,8	*	0,931	*	6,00	*	0,054	22,30	5,04
6	*	*	*	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*	*	*
8	7,11	2,0	*	*	13,0	*	0,968	0,348	7,40	*	0,080	27,50	6,2
9	*	*	*	*	*	*	*	*	*	*	*	*	*
10	7,06	2,0	4,0	*	13,6	*	*	*	*	*	0,046	30,10	6,8
11	7,15	2,0	4,0	*	14,2	*	*	*	*	*	0,034	31,50	7,1
12	7,21	2,0	4,0	*	14,7	*	*	0,273	*	*	0,046	30,60	6,9
13	*	*	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*	*	*
17	7,27	6,0	3,0	*	12,5	*	0,703	0,225	5,40	*	0,024	19,50	4,4
18	7,30	5,0	2,0	*	12	*	0,801	0,222	5,60	*	0,022	19,90	4,5
19	7,28	7,0	2,0	*	11,6	*	0,733	0,225	5,20	*	0,043	18,60	4,2
20	*	*	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*	*
22	7,32	5,0	5,0	*	15,4	*	0,810	0,388	6,02	*	0,031	21,70	4,9
23	*	*	*	*	*	*	*	*	*	*	*	*	*
24	7,30	5,0	5,0	*	16,4	*	0,787	0,348	6,30	*	0,020	22,60	5,1
25	7,18	7,0	5,4	<30	18,43	<20(2.8)	0,630	0,171	4,82	282,0	0,067	*	*
26	7,50	5,0	6,0	*	17	*	0,861	0,275	5,70	*	0,027	19,50	4,4
27	*	*	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*	*	*
29	7,40	2,0	5,0	*	15,2	*	0,993	0,345	6,20	*	0,043	23,70	5,35
30	*	*	*	*	*	*	*	*	*	*	*	*	*
	*	*	*	*	*	*	*	*	*	*	*	*	*
Media	7,227	4,000	3,814	*	14,109	2,800	0,823	0,282	5,826	282,000	0,046	23,329	5,265
CMA													

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Șef laborator