

IESIRE

-mg/l -

Data	pH	Susp. Tot.	CBO5	CCO- Cr	Extr.	Amoniu	*Fosfor tot.	*Deterg.	*Cianuri	*Sulfaji	*Crom total	Zinc
1	*	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*	*	*	*
7	7,10	8,00	9,09	32,47	<20(3.6)	1,694	1,33	0,10	0,00	101,00	0,00	0,15
8	*	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*	*
13	7,08	6,00	9,25	33,86	*	0,927	1,02	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*	*
20	7,12	5,00	9,40	32,15	<20(2.8)	0,804	0,98	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*	*
Media	7,10	6,33	9,25	31,36	3,60	1,14	1,11	0,10	0,00	101,00	0,00	0,15
CMA	6.5-8.5	3500	300	500	30	30	15	25	1	600	1,5	1

*Încercările marcate cu \* sau hasurate NU sunt acoperite de acreditarea RENAR*

*Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei*

*Prezenta raportare este doar pentru uzul intern*

**Întocmit**  
**Responsabil calitate**

**Avizat**  
**Șef laborator**