

IESIRE

-mg/l -

Data	pH	Susp. Tot.	CBO5	CCO- Cr	Extr.	Amoniu	*Fosfor tot.	*Deterg.	*Cianuri	*Sulfați	*Crom total	*Zinc
1	*	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*	*
3	6.64	8.00	5.90	<30(24.71)	<20(3.6)	0.709	0.81	0.11	0.00	50.00	0.00	0.00
4	*	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*	*
12	7.11	10.00	14.22	36.66	<20(3.6)	0.904	1.30	0.60	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*	*
18	6.93	8.00	18.27	45.96	<20(3.2)	0.912	1.13	0.90	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*	*
28	7.20	11.00	12.90	43.16	*	0.814	0.90	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*	*
Media	6.97	9.250	12.823	37.623	3.460	0.835	1.035	0.537	0.000	50.000	0.000	0.000
CMA	5.5-8.4	35	25	125	20	30	2	0.5	0.1	600	1	0.5

**Încercările marcate cu \* si/sau hasurate NU sunt acoperite de acreditarea RENAR**

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezentarea raportare este doar pentru uzul intern