

Intrare Stație -mg/l -

Data	pH	Susp. totale	CBO5	CCO-Cr	Extr.	*Fosfor total	*Deterg.	*Azot total	Reziduu	Amoniu	Azotati
1	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*
4	6,98	132,0	64,34	160,49	<20(8.8)	4,71	3,20	18,9	688	21,4	4,92
5	7,55	27,0	35,00	78,1	*	*	*	*	*	*	*
6	7,41	28,0	*	*	*	*	*	*	*	*	*
7	7,31	23,0	54,00	107,00	*	*	3,24	*	*	*	*
8	7,33	25,0	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*
11	6,92	131,0	65,67	146,73	*	3,89	*	17,3	690,4	*	*
12	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*
18	6,89	120,0	68,0	154,71	*	4,3	*	20,1	670	14,1	6,83
19	7,38	36,0	39,0	88,8	*	*	*	*	*	*	*
20	7,45	40,0	*	*	*	*	*	*	*	*	*
21	7,48	46,0	41,0	92,000	*	*	*	*	*	*	*
22	7,44	38,0	*	*	*	*	3,86	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*
25	7,65	26,0	39,0	85,6	*	1,93	2,58	21,0	*	*	1,21
26	*	*	*	*	*	*	*	*	*	*	*
27	7,57	29,0	40,0	90,1	*	1,91	*	20,4	*	15,4	3,36
28	7,52	45,0	*	*	*	*	*	*	*	*	*
29	7,47	63,0	50,0	111,000	*	1,7	*	22,0	*	14,3	2,55
30	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*
Media	7,357	53,933	49,601	111,453	8,800	3,073	3,220	19,950	682,800	16,300	3,774
CMA	6.5-8.5	350,00	300,00	500,00	30,00	5,00	25,00	*	2000,00		

Încercările marcate cu \* sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit  
 Responsabil calitate

Avizat  
 Șef laborator