

-mg/l -

Data	pH	Susp.	CBO5	CCO- Cr	Extr.	Amoniu	Fosfor	*Detergenți	Sulfuri	Cianuri	Sulfati	Crom	Zinc
		totale					total					total	
1	*	*	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*	*
15	7,33	68,00	78,58	196,81	<20(10.2)	17,12	2,51	3,30	2,960	0,00	42,00	0,00	0,10
16	*	*	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*	*	*
Media	7,33	68,00	78,58	196,81	10,20	17,12	2,51	3,30	2,960	0,000	42,00	0,00	0,100
CMA	6.5-8.5	350	300	500	30	30	15	25	15	1	600	1,5	1

**Încercările marcate cu \* si/sau hasurate NU sunt acoperite de acreditarea RENAR**  
**Rezultatele notate cu "<" reprezinta valorile situate sub limita de determinare a metodei**  
**Prezenta raportare este doar pentru uzul intern**

Sef laborator  
 chim. Hegedus Erika