

Intrare Stație -mg/l -

Data	pH	Susp. totale	CBO5	CCO-Cr	Extr.	*Fosfor total	*Deterg.	*Azot total	Reziduu	Amoniu	Azotati
1	7,37	48,0	*	*	*	*	*	*	*	*	*
2	7,41	43,0	47,00	105	*	*	*	*	*	*	*
3	7,39	79,0	*	*	*	*	4,76	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*
6	6,88	112,0	78,5	177,38	<20(11,6)	3,98	3,1	27,4	698,8	23,30	2,10
7	7,39	83,0	83,00	215	*	*	*	*	*	*	*
8	7,52	75,0	*	*	*	*	*	*	*	*	*
9	7,47	64,0	75,00	195	*	*	4,32	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*
14	7,44	386,0	*	*	*	4,34	*	35,4	*	21,4	5,660
15	6,96	142,0	80,39	192,96	*	3,51	2,8	28,6	602,8	23,3	*
16	7,37	68,0	*	*	*	*	3,86	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*	*	*
21	7,41	49,0	*	*	*	2,79	*	31,2	*	25,0	4,860
22	6,84	116,0	78,18	186,74	*	4,88	3,06	26,6	*	*	*
23	7,45	84,0	*	*	*	*	*	*	*	*	*
24	7,40	47,0	*	*	*	*	3,8	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*
27	7,35	50,0	*	*	*	3,24	*	29,3	*	24,6	3,310
28	7,37	57,0	98,00	220	*	*	*	*	*	*	*
29	7,35	125,0	*	*	*	*	*	*	*	*	*
30	7,43	72,0	*	*	*	*	4,25	*	*	*	*
	*	*	*	*	*	*	*	*	*	*	*
Media	7,322	94,444	77,153	184,583	11,600	3,790	3,744	29,750	650,800	23,520	3,983
CMA	6.5-8.5	350,00	300,00	500,00	30,00	5,00	25,00	*	2000,00		

Încercările marcate cu \* sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit  
 Responsabil calitate

Avizat  
 Șef laborator