

Intrare mg/l

Data	pH	Suspensii	CBO5	CCOCr	Extr.	*Fosf. Total	*Deterg.	*Azot total	Reziduu
1	7.60	31.00	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*
4	7.20	35.00	*	*	*	*	*	*	*
5	7.10	94.00	*	*	*	8.20	*	22.50	*
6	7.06	76.00	66.71	150.00	*	5.33	*	21.10	*
7	7.10	89.00	*	215.00	*	*	*	*	*
8	7.10	25.00	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*
11	7.20	89.00	*	*	*	*	*	*	*
12	7.50	76.00	*	*	*	9.41	*	18.40	*
13	7.52	244.00	323.47	681.00	*	28.00	*	26.40	*
14	7.70	112.00	*	298.00	*	*	*	*	*
15	7.20	116.00	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*
18	7.60	52.00	*	*	*	*	*	*	*
19	7.20	67.00	*	*	*	2.70	*	22.60	*
20	7.41	98.00	97.59	208.32	*	2.84	*	17.00	*
21	7.50	111.00	*	283.00	*	*	*	*	*
22	7.60	151.00	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*
25	7.60	54.00	*	*	*	*	*	*	*
26	7.50	80.00	*	*	*	2.92	*	26.80	*
27	7.65	248.00	52.80	117.41	*	2.59	*	21.00	828.00
28	7.60	39.00	*	292.00	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*
Media	7.40	94.35	135.14	280.59	12.00	7.75	#DIV/0!	21.98	828.00

Încercările marcate cu * si/sau hasurate NU sunt acoperite de acreditarea RENAR
Rezultatele notate cu "<" reprezinta valorile situate sub limita de determinare a metodei
Prezenta raportare este doar pentru uzul intern

Șef laborator
 chim. Hegedus Erika

Iesire mg/l

Data	pH	Suspensii	CBO5	CCOCr	Extr.	*Fosf. Total	*Deterg.	*Azot total	Reziduu
1	7.90	30.00	*	*	*	0.70	*	*	*
2	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*
4	7.40	21.00	*	64.20	*	0.59	*	*	*
5	7.70	30.00	*	*	*	1.85	*	*	*
6	7.55	26.00	15.30	61.50	<20(2.8)	1.29	0.11	11.30	438.00
7	7.30	34.00	*	82.10	*	1.10	*	*	*
8	7.30	28.00	*	*	*	1.54	*	*	*
9	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*
11	7.30	26.00	*	61.20	*	1.92	*	*	*
12	7.30	32.00	*	*	*	*	*	*	*
13	7.29	23.00	23.60	94.50	*	*	*	14.10	*
14	7.80	*	*	136.00	*	*	*	*	*
15	7.40	32.00	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*
18	7.19	16.00	15.80	52.81	<20(2.0)	1.83	0.20	14.00	488.00
19	7.40	29.00	*	*	*	1.76	*	*	*
20	7.44	27.00	22.40	63.81	*	1.83	*	10.30	*
21	7.10	30.00	*	73.00	*	1.65	*	*	*
22	7.80	35.00	*	*	*	1.63	*	*	*
23	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*
25	7.50	31.00	*	68.60	*	0.96	*	*	*
26	7.50	*	*	*	*	1.92	*	13.40	*
27	7.66	28.00	24.66	61.59	*	1.25	*	11.00	506.00
28	7.50	23.00	*	103.00	*	0.80	*	*	*
29	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*
Media	7.47	27.83	20.35	76.86	#DIV/0!	1.41	0.16	12.35	477.33
CMA	6.5-8.5	35	25	125	20	2	0.5	15	2000

Încercările marcate cu * si/sau hasurate NU sunt acoperite de acreditarea RENAR
Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei
Prezenta raportare este doar pentru uzul intern

Șef laborator
 chim. Hegedus Erika

