

Iesire mg/l

Data	pH	Suspensii	CBO5	CCOCr	Extr.	*Fosf. Total	*Deterg.	*Azot total	Reziduu
1	7.60	23.00	*	57.40	*	*	*	*	*
2	7.60	32.00	*	*	*	*	*	*	*
3	7.63	28.00	22.86	63.48	*	1.90	0.32	12.80	716.00
4	7.11	13.00	11.64	46.48	<20(2.8)	1.53	0.18	12.80	402.00
5	7.50	20.00	*	*	*	0.69	*	*	*
6	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*
8	7.70	19.00	*	53.60	*	1.51	*	*	*
9	7.70	15.00	*	*	*	1.27	*	*	*
10	7.26	30.00	16.05	65.56	*	1.50	0.30	12.60	716.00
11	7.50	34.00	*	70.30	*	*	*	*	*
12	7.50	18.00	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*
15	7.30	17.00	*	98.90	*	1.87	*	*	*
16	7.50	19.00	*	*	*	1.98	*	*	*
17	7.39	11.00	16.70	42.13	<20(2.4)	0.90	0.16	13.10	606.00
18	7.70	26.00	*	47.20	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*
23	7.50	16.00	*	*	*	0.51	*	*	*
24	*	*	*	*	*	*	*	*	*
25	7.70	17.00	*	49.00	*	0.64	*	*	*
26	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*
Media	7.51	21.13	16.81	59.41	2.60	1.30	0.24	12.83	610.00
CMA	6.5-8.5	35	25	125	20	2	0.5	15	2000

**Încercările marcate cu \* si/sau hasurate NU sunt acoperite de acreditarea RENAR**  
**Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei**  
**Prezenta raportare este doar pentru uzul intern**

Şef laborator  
 chim. Hegedus Erika

