

Intrare mg/l

Data	pH	Suspensii	CBO5	CCOCr	Extr.	*Fosf. Total	*Deterg.	*Azot total	Reziduu
1	8.10	32.00	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*
4	7.70	61.00	*	*	*	*	*	*	*
5	7.60	90.00	*	*	*	3.38	*	29.90	*
6	7.64	176.00	114.74	265.54	12.40	3.51	2.90	21.30	910.00
7	7.70	52.00	*	134.00	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*
11	7.60	89.00	*	*	*	*	*	*	*
12	7.30	53.00	*	*	*	2.71	*	28.80	*
13	7.68	174.00	154.64	324.18	*	8.94	*	25.60	926.00
14	7.50	160.00	*	220.00	*	*	*	*	*
15	7.60	271.00	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*
18	7.50	51.00	*	*	*	*	*	*	*
19	7.40	73.00	*	*	*	3.10	*	26.70	*
20	7.31	72.00	72.34	172.00	11.20	3.23	2.37	29.50	918.00
21	7.60	55.00	*	158.00	*	*	*	*	*
22	7.60	50.00	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*
25	7.50	60.00	*	*	*	*	*	*	*
26	7.60	70.00	*	*	*	3.10	*	24.60	*
27	7.64	94.00	158.98	337.20	*	8.60	*	28.10	916.00
28	7.40	75.00	*	164.00	*	*	*	*	*
29	7.50	75.00	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*
Media	7.57	91.65	125.18	221.87	11.80	4.57	2.64	26.81	917.50

Încercările marcate cu * si/sau hasurate NU sunt acoperite de acreditarea RENAR
Rezultatele notate cu "<" reprezinta valorile situate sub limita de determinare a metodei
Prezenta raportare este doar pentru uzul intern

Şef laborator
chim. Hegedus Erika

Iesire mg/l

Data	pH	Suspensii	CBO5	CCOCr	Extr.	*Fosf. Total	*Deterg.	*Azot total	Reziduu
1	7.70	17.00	*	*	*	0.82	*	*	*
2	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*
4	7.50	*	*	81.60	*	1.37	*	*	*
5	7.50	27.00	*	*	*	*	*	*	*
6	7.60	34.90	24.62	63.04	<20(2.8)	1.20	0.11	*	527.00
7	7.50	34.00	*	69.70	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*
11	7.60	21.00	*	55.30	*	1.13	*	*	*
12	7.50	21.00	*	*	*	1.14	*	*	*
13	7.58	21.00	23.89	58.32	*	1.38	*	14.60	612.00
14	7.60	25.00	*	66.70	*	1.53	*	*	*
15	7.60	31.00	*	*	*	1.63	*	*	*
16	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*
18	7.50	23.00	*	62.20	*	1.79	*	*	*
19	7.06	11.00	20.57	50.37	<20(2.4)	0.97	0.12	*	708.00
20	7.19	27.00	23.22	62.60	*	1.93	*	13.80	*
21	7.60	35.00	*	72.40	*	*	*	*	*
22	7.60	35.00	*	*	*	1.46	*	*	*
23	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*
25	7.40	24.00	*	82.30	*	1.27	*	*	*
26	7.40	35.00	*	*	*	1.26	*	*	*
27	7.56	33.00	24.67	72.41	*	2.00	*	*	772.00
28	7.70	28.00	*	67.60	*	*	*	*	*
29	7.50	26.00	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*
Media	7.51	26.78	23.39	66.50	2.60	1.39	0.12	14.20	654.75
CMA	6.5-8.5	35	25	125	20	2	0.5	15	2000

Încercările marcate cu * si/sau hasurate NU sunt acoperite de acreditarea RENAR
Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei
Prezenta raportare este doar pentru uzul intern

Şef laborator
chim. Hegedus Erika

