

IESIRE												
-mg/l -												
Data	pH	Susp. Tot.	CBO5	CCO- Cr	Extr.	Amoniu	*Fosfor tot.	*Deterg.	*Cianuri	*Sulfați	*Crom total	*Zinc
1	*	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*	*
6	7.03	10.00	5.26	<30(24.33)	<20(2.8)	1.16	1.71	0.10	0.000	66.00	0.000	0.100
7	*	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*	*
13	7.06	13.00	6.66	26.80	<20(2.8)	1.32	1.12	0.10	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*	*
20	7.11	15.00	6.55	26.20	<20(2.8)	2.60	0.96	1.80	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*	*
27	7.28	11.00	9.90	39.60	<20(3.2)	1.99	1.66	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*	*
Media	7.12	12.250	7.093	30.867	2.933	1.768	1.363	0.667	0.000	66.000	0.000	0.100
CMA	5.5-8.4	35	25	125	20	30	2	0.5	0.1	600	1	0.5

Încercările marcate cu * și/sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern