

Intrare, mg/l

Data	pH	Suspensii	CBO5	CCOCr	Extr.	Amoniu	*Fosf. total	*Deterg. total	*Azot total	Reziduu	*Fier total	*Mangan
1	7,64	320,00	153,74	374,40	*	28,54	4,20	*	42,40	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*	*
3	7,57	300,00	149,85	357,24	<20(13.2)	29,87	4,51	3,98	46,20	899,20	0,50	0,30
4	*	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*	*
6	7,12	295,00	170,10	378,00	*	26,90	3,92	*	41,60	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*	*
10	7,59	288,00	*	*	*	29,50	4,40	*	44,60	*	*	*
11	7,54	312,00	162,78	401,80	<20(12.8)	26,35	4,10	4,06	39,80	788,00	0,40	0,30
12	*	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*
15	7,50	296,00	166,90	417,77	*	26,81	4,30	*	39,70	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*
22	7,37	304,00	138,15	345,39	*	29,87	4,60	*	42,80	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*
24	7,31	296,00	152,83	382,08	*	27,54	3,87	*	39,80	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*	*
26	7,50	357,00	160,87	402,19	*	28,34	4,11	*	40,60	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*	*
29	7,33	344,00	146,71	366,79	*	26,22	4,04	*	41,40	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*	*
Media	7,45	311,20	155,77	380,63	13,00	27,99	4,21	4,02	41,89	843,60	0,45	0,30

*Incercările marcate cu \* sau hasurate NU sunt acoperite de acreditarea RENAR*

*Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei*

*Prezenta raportare este doar pentru uzul intern*

**Întocmit**  
**Responsabil calitate**

**Avizat**  
**Șef laborator**