

IESIRE												
-mg/l -												
Data	pH	Susp. Tot.	CBO5	CCO- Cr	Extr.	Amoniu	*Fosfor tot.	*Deterg.	*Cianuri	*Sulfați	*Crom total	Zinc
1	*	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*	*	*	*
7	6,98	9,00	7,39	42,43	<20(6.0)	0,591	1,50	0,10	0,00	20,00	0,00	0,07
8	*	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*	*
19	6,98	8,00	12,47	49,92	*	0,615	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*
24	7,43	2,0	4,00	14,80	*	0,031	0,693	*	*	*	*	*
25	7,41	2,0	3,00	13,60	*	0,035	0,704	*	*	*	*	*
26	7,40	2,0	5,00	16,00	*	0,042	0,718	*	*	*	*	*
27	7,42	2,0	5,00	17,30	*	0,065	0,810	*	*	*	*	*
28	7,38	2,00	*	18,00	*	0,180	0,901	*	*	*	*	*
29	7,35	3,00	*	17,10	*	0,075	0,920	*	*	*	*	*
30	7,42	3,00	*	18,60	*	0,067	0,900	*	*	*	*	*
31	7,39	3,00	*	13,80	*	0,031	0,891	*	*	*	*	*
Media	7,316	3,600	6,143	43,550	6,000	0,173	0,893	0,100	0,000	20,000	0,000	0,070
CMA	6.5-8.5	3500	300	500	30	30	15	25	1	600	1,5	1

*Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR*

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Șef laborator