

Intrare Stație -mg/l -

Data	pH	Susp. totale	CBO5	CCO-Cr	Extr.	*Fosfor total	*Deterg.	*Azot total	Reziduu	Amoniu	Azotati
1	7,61	76,0	*	120	*	2,33	5,45	28,2	*	35,3	3,06
2	7,65	106,0	*	138	*	2,57	4,87	27,9	*	34,05	3,48
3	*	*	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*
22	7,65	64	*	140	*	3,07	5,2	25,4	*	26,2	6,62
23	7,54	75	*	*	*	*	*	*	*	*	*
24	7,52	61	*	160	*	2,97	4,91	27,2	*	26,4	6,840
25	7,57	70	*	150	*	3,04	5,14	25,7	*	23,47	4,660
26	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*
28	7,52	60	*	115	*	1,55	4,09	14,4	*	14,00	3,84
29	7,54	45,0	*	102	*	1,7	4,33	17	*	14,31	4,010
30	7,57	48,0	*	98	*	1,68	8,69	14,1	*	15,48	3,74
31	*	*	*	*	*	*	*	*	*	*	*
Media	7,574	67,222	#DIV/0!	127,875	9,200	2,364	5,335	22,488	#DIV/0!	23,651	4,531
CMA	6.5-8.5	350,00	300,00	500,00	30,00	5,00	25,00	*	2000,00		

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Șef laborator