

Indicatori de calitate – luna MAI/ 2019
 Stația de epurare SATU MARE - probe medii zilnice

Evacuare, mg/l

Data	pH	Suspensii	CBO5	CCOCr	Extr.	Amoniu	*Fosf. total	*Deterg.	*Azot total	*Azotati	Reziduu	*Fier total	*Mangan
1	*	*	*	*	*	*	*	*	*	*	*	*	*
2	7.28	12.00	5.26	<30(24.52)	*	<0.063(0.024)	0.478	*	5.53	14.10	*	*	*
3	7.31	*	*	*	*	0.093	0.440	*	6.10	*	*	*	*
4	7.30	11.00	6.04	25.20	*	0.933	0.312	*	8.71	26.20	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*	*	*
6	7.49	*	*	*	*	0.130	0.390	*	7.68	*	*	*	*
7	7.36	10.00	6.24	<30(26.02)	*	<0.063(0.014)	0.413	*	4.17	12.50	*	*	*
8	7.16	*	*	*	*	<0.063(0.009)	0.375	*	5.80	*	*	*	*
9	7.31	4.00	2.54	<30(22.7)	<20(2.4)	<0.063(0.019)	0.221	0.11	6.16	21.30	386.00	0.30	0.01
10	7.29	*	*	*	*	0.180	0.300	*	6.08	*	*	*	*
11	6.56	12.00	6.35	25.40	*	0.043	0.806	*	8.14	28.20	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	0.120	0.660	*	7.90	*	*	*	*
14	7.73	11.00	5.69	<30(22.86)	*	1.160	0.450	*	9.14	24.20	*	*	*
15	7.19	*	*	*	*	<0.063(0.049)	0.430	*	6.57	*	*	*	*
16	7.21	5.00	5.63	<30(24.52)	*	<0.063(0.03)	0.217	*	8.06	22.40	*	*	*
17	7.37	10.00	*	*	*	0.927	0.200	*	7.90	28.90	*	*	*
18	7.32	15.00	6.20	24.80	*	0.380	0.620	*	6.81	27.30	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*	*	*
20	6.85	3.00	4.46	<30(22.36)	<20(2.0)	0.338	0.237	0.10	8.79	29.00	360.00	0.20	0.09
21	7.58	5.00	*	*	*	0.721	0.290	*	7.60	*	*	*	*
22	7.31	*	*	<30(25.89)	*	0.290	0.330	*	7.20	*	*	*	*
23	7.20	4.00	6.42	<30(25.08)	*	0.400	0.260	*	7.60	*	*	*	*
24	*	*	*	*	*	0.180	0.420	*	8.10	*	*	*	*
25	6.99	3.00	8.52	35.50	*	0.190	0.390	*	6.66	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*	*	*
27	7.08	3.00	*	*	*	0.210	0.580	*	7.08	*	*	*	*
28	7.30	3.00	*	*	*	0.110	0.700	*	7.12	*	*	*	*
29	*	*	*	*	*	0.260	0.680	*	7.40	*	*	*	*
30	6.81	4.00	6.40	25.60	*	<0.063(0.02)	0.890	*	8.55	*	*	*	*
31	6.58	2.00	*	*	*	<0.063(0.024)	0.600	*	4.60	11.70	*	*	*
Media	7.199	6.882	5.813	25.419	2.200	0.264	0.450	0.105	7.133	22.345	373.000	0.250	0.050

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR
Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei
Prezenta raportare este doar pentru uzul intern

Șef laborator
 chim. Hegedus Erika