

Stația de epurare Tășnad

mg/l

Data	pH	Suspensii	CBO5	CCO-Cr	Extractibile	Amoniu	Reziduu	*Detergenti
1	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*
6	7.25	59.00	23.48	117.70	<20 (8.8)	8.00	*	0.35
7	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*
11	7.80	150.50	69.40	231.50	<20(14.4)	36.00	506.00	0.43
12	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*
20	7.40	87.00	26.80	146.00	<20(11.2)	8.20	516.00	0.21
21	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*
27	7.58	60.00	23.60	119.00	<20(19.6)	*	580.00	0.36
28	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*
Media	7.51	89.13	35.82	153.55	13.50	17.40	534.00	0.34
CMA	6.5-8.5	60.00	25	125	20	3	2000	0.5

↑ **Încercările marcate cu * si/sau hasurate NU sunt acoperite de acreditarea RENAR**

Rezultatele notate cu "<" reprezinta valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Șef laborator

chim. Hegedus Erika