

Data	pH	Suspensii	CBO5	CCO-Cr	Extractibile	Amoniu	Reziduu	*Detergenti
1	*	*	*	*	*	*	*	*
2	7.55	308.00	186.92	467.32	<20(18.0)	26.449	506.00	0.60
3	7.79	142.00	79.52	190.45	<20(14.0)	20.259	510.00	0.59
4	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*
10	7.46	174.00	159.14	354.20	<20(9.2)	23.824	532.00	0.41
11	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*
17	7.54	152.00	99.87	216.41	<20(12.4)	26.600	514.00	0.50
18	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*
Media	7.59	194.00	131.36	307.10	13.40	24.28	515.50	0.53
CMA	6.5-8.5	350.00	300	500	30	30	2000	25

Încercările marcate cu * și/sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezența raportare este doar pentru uzul intern

Șef laborator

chim. Hegedus Erika