

mg/l

Data	pH	Suspensii	CBO5	CCO-Cr	Extractibile	Amoniu	Reziduu	*Detergenti
1	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*
3	7.49	229.00	149.31	362.13	<20(7.6)	25.200	510.00	0.660
4	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*
12	7.83	135.00	88.85	216.11	<20(11.2)	29.200	508.00	0.680
13	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*
19	7.43	71.00	41.61	103.16	<20(12.4)	25.300	496.00	*
20	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*
26	7.48	102.00	67.02	169.77	<20(11.2)	24.200	550.00	0.560
27	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*
Media	7.558	134.250	86.698	212.793	10.600	25.975	516.000	0.633
CMA	6.5-8.5	350.00	300	500	30	30	2000	25

Încercările marcate cu * și/sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezența raportare este doar pentru uzul intern

Șef laborator

chim. Hegedus Erika