

Indicatori de calitate – luna IANUARIE/2024
 Stația de epurare Livada

IESIRE		-mg/l -							
Data	Cod proba	pH	Susp. Tot.	CBO5	CCO- Cr	Extr.	Amoniu	Reziduu	*detergenti
1	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*
26	P66	7,50	16,00	12,60	56,06	<20(8.8)	0,608	446,00	0,21
27	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*
Media	*	7,500	16,000	12,600	56,060	8,800	0,608	446,000	0,210
CMA	*	6.5-8.5	60	25	125	20	3	2000	0,5

*Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR
 Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei
 Prezentă raportare este doar pentru uzul intern*

Întocmit
Responsabil calitate

Avizat
Şef laborator