

Indicatori de calitate – luna IULIE/2026
Stația de epurare Mediesu Aurit

EVACUARE, apa uzata

-mg/l -

Data	Cod Proba	pH	Suspensii	CBO5	CCOCr	Extr.	*Deterg.	Amoniu	Reziduu
1	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	**	*
3	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*
23	P610	7,6	18,00	13,24	54,47	<20(5.2)	0,37	1,95	458,00
24	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*
Media	*	7,60	18,00	13,24	54,47	5,20	0,370	1,950	458,00
CMA	*	6.5-8.5	60,00	25,000	125,00	20,00	0,500	3,000	2000,00

*Incercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR*

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator