

Indicatori de calitate – luna AUGUST/2025
Stația de epurare Negrești Oas

EVACUARE, apa uzata

-mg/l -

Data	Cod	pH	Susp.	CBO5	CCO- Cr		Extr.	Fosfor	*Deterg.	Azot	Reziduu
	Proba		totale					total		total	
1	*	7,23	14	*	*	*	*	*	*	10,1	*
2	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*
4	*	6,82	17	*	*	*	*	*	*	*	*
5	*	6,93	*	13	*	44,2	*	*	*	*	*
6	P619	6,9	5	7,08	<30	27,96	<20(3.6)	0,783	0,38	11,78	400
7	*	7,41	15	18	*	87,1	*	*	*	*	*
8	*	7,38	20	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*
11	*	7,13	30	*	*	*	*	*	*	*	*
12	*	7,02	19	16	*	56,5	*	*	*	*	*
13	*	7,06	24	*	*	*	*	*	*	*	*
14	*	7,09	19	13	*	45,6	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*
18	*	7,15	11	*	*	*	*	*	*	*	*
19	*	7,21	14	23	*	79,7	*	*	*	*	*
20	*	7,25	15	*	*	*	*	*	*	*	*
21	*	7,31	22	21	*	72,6	*	*	*	*	*
22	*	7,25	25	*	*	*	*	*	*	13,1	*
23	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*
25	*	7,22	3	*	*	*	*	*	*	7,69	*
26	*	7,20	10	7	*	25,1	*	*	*	*	*
27	*	7,15	9	*	*	*	*	*	*	8,76	*
28	*	7,10	14	8	*	25,4	*	*	*	*	*
29	*	7,19	20	*	*	*	*	*	*	9,92	*
30	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*
Media	*	7,150	16,105	14,009	*	27,90	3,600	0,783	0,380	10,225	400,000
CMA	*	6.5-8.5	35,00	25,00	*	125,0	20,00	2,00	0,50	15,00	2000,0

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezentarea raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator