

Indicatori de calitate – luna DECEMBRIE/2025
Stația de epurare Negrești Oas

EVACUARE, apa uzata

-mg/l -

Data	Cod	pH	Susp.	CBO5	CCO- Cr		Extr.	Fosfor	*Deterg.	Azot	Reziduu
	Proba		totale					total		total	
1	*	*	*	*	*	*	*	*	*	*	*
2	P958	7,0	6,0	8,54	*	31,82	<20(4.0)	0,801	0,460	13,50	492,4
3	*	7,06	19	*	*	*	*	*	*	12,90	*
4	*	7,09	20	10	*	39,20	*	0,629	*	*	*
5	*	7,10	22	*	*	*	*	*	*	12,30	*
6	*	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*
8	*	7,11	20	*	*	*	*	*	*	13,80	*
9	*	7,09	24	12	*	46,40	*	*	*	*	*
10	*	7,10	26	*	*	*	*	*	*	12,00	*
11	*	7,12	17	8	*	37,40	*	1,500	*	*	*
12	*	7,15	29	*	*	*	*	*	*	12,40	*
13	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*
15	*	7,11	28	*	*	*	*	*	*	13,10	*
16	*	7,13	22	7	*	35,60	*	*	*	*	*
17	*	7,15	16	*	*	*	*	*	*	12,90	*
18	*	7,05	18	11	*	48,30	*	*	*	*	*
19	*	7,02	23	*	*	*	*	*	*	14,30	*
20	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*
	*	*	*	*	*	*	*	*	*	*	*
Media	*	7,091	20,714	9,423	*	39,79	4,000	0,977	0,460	13,022	492,400
CMA	*	6.5-8.5	35,00	25,00	*	125,0	20,00	2,00	0.50	15,00	2000,0

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezentarea raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator