

Indicatori de calitate – luna IANUARIE/2026
Stația de epurare Negrești Oas

EVACUARE, apa uzata

-mg/l -

Data	Cod	pH	Susp.	CBO5	CCO- Cr	Extr.	Fosfor	*Deterg.	Azot	Reziduu	
	Proba		totale				total		total		
1	*	*	*	*	*	*	*	*	*	*	
2	*	*	*	*	*	*	*	*	*	*	
3	*	*	*	*	*	*	*	*	*	*	
4	*	*	*	*	*	*	*	*	*	*	
5	*	*	*	*	*	*	*	*	*	*	
6	*	*	*	*	*	*	*	*	*	*	
7	*	*	*	*	*	*	*	*	*	*	
8	*	6,96	26,0	8,0	*	38,7	*	*	*	*	
9	P4	6,9	18,0	7,7	*	30,87	<20(4.4)	0,790	0,32	13,1	428,4
10	*	*	*	*	*	*	*	*	*	*	
11	*	*	*	*	*	*	*	*	*	*	
12	*	6,90	*	12,0	*	*	*	*	*	*	
13	*	6,87	*	11,0	*	*	*	*	*	*	
14	*	6,99	*	*	*	*	*	*	14,8	*	
15	*	7,00	*	11,0	*	54,5	*	*	*	*	
16	*	6,90	18,0	*	*	*	*	*	14,3	*	
17	*	*	*	*	*	*	*	*	*	*	
18	*	*	*	*	*	*	*	*	*	*	
19	*	6,86	*	*	*	*	*	*	9,02	*	
20	*	6,81	7,0	8,0	*	43,9	*	*	*	*	
21	*	6,79	9,0	*	*	*	*	*	8,69	*	
22	*	6,77	12,0	7,0	*	37,1	*	*	*	*	
23	*	6,80	11,0	*	*	*	*	*	8,58	*	
24	*	*	*	*	*	*	*	*	*	*	
25	*	*	*	*	*	*	*	*	*	*	
26	*	6,93	6,0	*	*	*	*	*	8,4	*	
27	*	6,95	7,0	5,0	*	20,3	*	0,373	*	*	
28	*	6,91	7,0	*	*	*	*	*	8,8	*	
29	*	7,00	11,0	6,0	*	21,7	*	0,407	*	*	
30	*	7,02	8,0	*	*	*	*	*	9,0	*	
	*	*	*	*	*	*	*	*	*	*	
Media	*	6,904	11,667	8,411	*	35,30	4,400	0,523	0,320	10,519	428,400
CMA	*	6.5-8.5	35,00	25,00	*	125,0	20,00	2,00	0,50	15,00	2000,0

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezentarea raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator