

Intrare Stație -mg/l -

Data	Cod	pH	Susp.	CBO5	CCO-	Extr.	Fosfor	*Deterg.	Azot	Reziduu	Amoniu
	Proba		totale		Cr		total		total		
1	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*
15	*	7,49	208	*	*	*	*	*	*	*	*
16	*	7,52	59	36	115	*	3,03	*	*	*	*
17	*	7,60	58	*	*	*	*	*	28,2	*	*
18	*	7,44	35	34	95,7	*	*	*	*	*	*
19	*	7,52	61	*	*	*	*	*	49,0	*	*
20	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*
22	*	7,50	51	*	*	*	*	*	43,2	*	*
23	P557	7,0	80	64,5	150,92	*	5,3	*	40,2	*	*
24	*	7,41	94	*	*	*	*	*	40,7	*	*
25	*	7,46	65	78	220	*	3,74	*	*	*	*
26	*	7,50	73	*	*	*	*	*	48,8	*	*
27	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*
29	*	7,53	92	*	*	*	*	*	*	*	*
30	*	7,52	83	67	188	*	*	*	*	*	*
31	*	7,54	90	*	*	*	*	*	*	*	*
Media	*	7,464	80,692	55,900	153,924	*	4,023	#####	41,683	*	#####
CMA	*	6.5-8.5	350,00	300,00	500,00	30,00	5,00	25,00	*	2000,00	

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator