

Indicatori de calitate – luna IUIE/2026
Stația de epurare Negresti Oas

EVACUARE, apa uzata

-mg/l -

Data	Cod	pH	Susp.	CBO5	CCO- Cr		Extr.	Fosfor	*Deterg.	Azot	Reziduu
	Proba		totale					total		total	
1	*	6,88	*	*	*	*	*	*	*	*	*
2	P547	6,8	16,0	10,75	*	46,19	<20(6.4)	0,825	0,33	4,2	500
3	*	6,93	24	*	*	*	*	*	*	*	*
4	*	*	*	*	*	*	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*
6	*	7,1	24	*	*	*	*	*	*	*	*
7	*	6,71	26	5	*	20,3	*	*	*	*	*
8	*	6,86	*	*	*	*	*	*	*	*	*
9	*	6,8	25	7	*	33,6	*	*	*	*	*
10	*	6,71	*	*	*	*	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*
20	*	6,83	*	*	*	*	*	*	*	*	*
21	*	6,88	*	16	*	84,6	*	*	*	*	*
22	*	6,85	*	*	*	*	*	*	*	*	*
23	*	6,83	20	11	*	44,4	*	*	*	*	*
24	*	6,81	22	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*
27	*	6,62	*	*	*	*	*	*	*	*	*
28	*	7,05	*	10	*	41	*	*	*	*	*
29	*	7,07	*	*	*	*	*	*	*	*	*
30	*	6,94	19	8	*	38,4	*	*	*	*	*
31	*	6,92	15	*	*	*	*	*	*	*	*
Media	*	6,866	21,222	9,679	*	44,070	6,400	0,825	0,330	4,200	500,000
CMA	*	6.5-8.5	35,00	25,00	*	125,0	20,00	2,00	0.50	15,00	2000,0

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezentă raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator