

Indicatori de calitate – luna IUNIE/2026
Stația de epurare Negresti Oas

EVACUARE, apa uzata

-mg/l -

Data	Cod	pH	Susp.	CBO5	CCO- Cr		Extr.	Fosfor	*Deterg.	Azot	Reziduu
	Proba		totale					total		total	
1	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*
4	P451	7,1	20,0	8,77	*	32,56	<20(6.0)	0,331	0,33	4,2	450
5	*	*	*	*	*	*	*	*	*	*	*
6	*	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*
9	*	6,99	*	*	*	43,8	*	*	*	*	*
10	*	6,78	*	*	*	31,7	*	*	*	*	*
11	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*
16	*	6,80	19	*	*	33	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*
18	*	7,06	17	*	*	30,5	*	*	*	*	*
19	*	7,08	15	*	*	*	*	*	*	*	*
20	*	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*
23	*	7,14	16	*	*	38,5	*	*	*	*	*
24	*	7,12	18	*	*	*	*	*	*	*	*
25	*	7,22	*	*	*	13,1	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*
30	*	6,9	*	*	*	45	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*
Media	*	7,019	17,500	8,770	*	33,520	6,000	0,331	0,330	4,200	450,000
CMA	*	6.5-8.5	35,00	25,00	*	125,0	20,00	2,00	0.50	15,00	2000.0

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezinta valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator