

Intrare Stație -mg/l -

Data	Cod	pH	Susp.	CBO5	CCO-	Extr.	Fosfor	*Deterg.	Azot	Reziduu	Amoniu
	Proba		totale		Cr		total		total		
1	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*
4	*	7,64	44	*	*	*	*	*	39,7	*	25,9
5	*	7,61	40	54	146,0	*	5,7	*	*	*	*
6	*	7,53	72	*	*	*	*	*	48,3	*	26,1
7	*	7,57	52	37	104,0	*	3,67	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*
10	*	*	*	*	*	*	*	*	*	*	*
11	*	7,58	93	*	*	*	*	*	43,4	*	26,3
12	*	7,60	292	95	240,0	*	3,68	*	*	*	*
13	P190	7,3	119	62	149,0	*	1,47	2,34	17,6	*	11,4
14	*	7,40	44	40	114,0	*	1,51	*	*	*	*
15	*	7,43	52	*	*	*	*	*	22,5	*	13,02
16	*	*	*	*	*	*	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*
18	*	7,71	66	*	*	*	*	*	37,1	*	25
19	*	7,67	46	46	127,0	*	3,96	*	*	*	*
20	*	6,60	151	*	*	*	*	*	40,5	*	25,7
21	*	7,54	88	71	189,0	*	4,01	*	*	*	*
22	*	7,50	73	*	*	*	*	*	42,6	*	26
23	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*
25	*	7,55	75	*	*	*	*	*	54,5	*	33,8
26	*	7,65	87	43	115,0	*	4,03	*	*	*	*
27	*	7,71	83	*	*	*	*	*	44,1	*	25,9
28	*	7,77	75	37	104,0	*	3,99	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*
Media	*	7,520	86,222	53,889	143,112	*	3,558	2,340	39,030	*	23,912
CMA	*	6.5-8.5	350,00	300,00	500,00	30,00	5,00	25,00	*	2000,00	

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Șef laborator