

Indicatori de calitate – luna Martie/2025
 Stația de epurare Negrești Oas

EVACUARE, apa uzata

-mg/l -

Data	Cod	pH	Susp.	CBO5	CCO- Cr		Extr.	Fosfor	*Deterg.	Azot	Reziduu
	Proba		totale					total		total	
1	*	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*	*
3	*	6,71	10	*	*	*	*	*	*	*	*
4	P176	7	5	7,92	*	30,87	<20(4.0)	0,194	0,21	12,4	346
5	*	6,70	7	*	*	*	*	*	*	*	*
6	*	6,72	6	3,0	*	12,9	*	0,287	0,19	*	*
7	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*	*
10	*	6,75	8	*	*	*	*	*	*	11,8	*
11	*	6,78	9	11,0	*	36,0	*	0,512	*	*	*
12	*	6,76	10	*	*	*	*	*	*	*	*
13	*	6,90	12	10,0	*	34,7	*	1,08	*	*	*
14	*	6,87	7	*	*	*	*	*	*	9,25	*
15	*	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*	*
17	*	6,65	4	*	*	*	*	*	*	3,38	*
18	*	6,68	3	4,0	*	14,7	*	0,528	*	*	*
19	*	6,71	4	*	*	*	*	*	*	5,83	*
20	*	6,75	5	5,0	*	20,0	*	0,131	*	*	*
21	*	6,81	6	*	*	*	*	*	*	6,50	*
22	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*
24	*	6,78	8	*	*	*	*	*	*	8,30	*
25	*	6,75	11	4,0	*	16,7	*	0,290	*	*	*
26	*	6,81	7	*	*	*	*	*	*	8,99	*
27	*	6,80	6	5,0	*	16,9	*	0,427	*	*	*
28	*	6,84	4	*	*	*	*	*	*	9,28	*
29	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*
31	*	6,91	9	*	*	*	*	*	*	*	*
Media	*	6,784	7,050	6,240	*	22,846	4,000	0,431	0,200	8,414	346,000
CMA	*	6.5-8.5	35,00	25,00	*	125,00	20,00	2,00	0,50	15,00	2000,0

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator