

Indicatori de calitate – luna NOIEMBRIE/2025
Stația de epurare Negresti Oas

INTRARE, apa uzata

-mg/l -

Data	Cod	pH	Susp.	CBO5	CCOCr	Extr.	Fosfor	*Deterg.	Azot	Reziduu
	Proba		totale				total		total	
1	*	*	*	*	*	*	*	*	*	*
2	*	*	*	*	*	*	*	*	*	*
3	*	7,61	153	*	*	*	*	*	63,5	*
4	P866	6,9	108	71,58	181,58	*	3,98	*	63,5	*
5	*	7,75	*	*	*	*	*	*	63,2	*
6	*	7,77	*	40	114,0	*	4,02	*	*	*
7	*	7,74	86	*	*	*	*	*	52,3	*
8	*	*	*	*	*	*	*	*	*	*
9	*	*	*	*	*	*	*	*	*	*
10	*	7,69	*	*	*	*	*	*	45,4	*
11	*	7,70	*	60	171,0	*	5,07	*	*	*
12	*	7,54	*	56	159,0	*	*	3,03	42,1	*
13	*	7,48	*	59	109,0	*	4,05	*	*	*
14	*	7,44	*	*	*	*	*	*	37,8	*
15	*	*	*	*	*	*	*	*	*	*
16	*	*	*	*	*	*	*	*	*	*
17	*	7,60	*	*	*	*	*	*	38,4	*
18	*	7,52	*	29	82,9	*	*	*	*	*
19	*	7,48	*	*	*	*	*	*	31,0	*
20	*	7,44	*	32	84,5	*	*	*	*	*
21	*	7,5	*	*	*	*	*	*	47,6	*
22	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*
24	*	7,48	*	*	*	*	*	*	23,6	*
25	*	7,44	*	26	77,0	*	*	*	*	*
26	*	7,49	*	*	*	*	*	*	24,5	*
27	*	7,39	*	*	*	*	*	*	25,4	*
28	*	7,41	*	30	84,7	*	3,40	*	*	*
29	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*
	*	*	*	*	*	*	*	*	*	*
Media	*	7,519	115,67	44,842	118,187	#####	4,104	3,030	42,946	#####
CMA	*	6.5-8.5	350,00	300,00	500,00	30,00	5,00	25,00		2000,0

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezentarea raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator