

Intrare Stație -mg/l -

Data	pH	Susp.	CBO5	CCO-	Extr.	*Fosfor	*Deterg.	*Azot	Reziduu	Amoniu
		totale		Cr		total		total		
1	7,62	70	*	*	*	*	*	31,3	*	24,6
2	7,66	96	47,0	142	*	3,48	*	*	*	*
3	7,6	84	*	*	*	*	*	31,5	*	25,41
4	7,5	63	39,0	113	*	2,75	*	*	*	*
5	7,5	106	*	*	*	*	*	30,2	*	24,5
6	*	*	*	*	*	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*
8	7,48	32	*	*	*	*	*	14,9	*	15,35
9	7,47	30	17,0	50,2	*	1,42	2,81	15,0	*	11,7
10	7,03	30	62,24	142,56	<20(9,6)	3,8	3,5	39,7	792	14,7
11	7,59	27	22,0	68	*	1,47	*	*	*	*
12	7,57	25	*	*	*	*	*	20,9	*	19,1
13	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*
15	7,59	40	*	*	*	*	*	25,2	*	20,2
16	7,54	48	27,0	80,3	*	1,53	*	*	*	*
17	7,5	41	*	*	*	*	*	24,3	*	21,7
18	7,72	48	33,0	99,9	*	1,9	*	*	*	*
19	7,68	28	*	*	*	*	*	26,6	*	22,7
20	*	*	*	*	*	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*
22	7,5	25	*	*	*	*	*	17,8	*	*
23	7,5	34	34,0	102	*	1,93	*	*	*	*
24	7,5	24	*	*	*	*	*	18,5	*	19,4
25	7,47	51	36,0	108	*	2,22	*	*	*	*
26	7,45	33	*	*	*	*	*	18,1	*	18,5
27	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*
Media	7,524	46,750	35,249	100,662	9,600	2,278	3,155	24,154	792,000	19,822
CMA	6.5-8.5	350,00	300,00	500,00	30,00	5,00	25,00	*	2000,00	

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Şef laborator